

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243612  
Address: 3538 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Kyle Beard	Failed	Monday, August 26, 2024

Corrective Action Required:

2	Miscellaneous Correction	-Remove paper facing on insulation for fire blocking -Fire block top plate penetrations -Vertically fire block corners -Secure electrical 12/2 wire above ceiling in bathroom to bedroom
---	--------------------------	---

**Comments:**