CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232358

Address: 452 SW BRUMMEL RD, LEES SUMMIT, MO 64081454 SW BRUMMEL RD, LEES SUMMIT, MO

64081456 SW BRUMMEL RD, LEES SUMMIT, MO 64081458 SW BRUMMEL RD, LEES

SUMMIT, MO 64081450 SW BRUMMEL RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Shawn Hoffman Partial Monday, August 26,

Commercial 2024

Corrective Action Required:

1 Misc Gargages Building 4

- Provide attic access

-Nail patern for shear walls approved

Comments: