

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234376
Address: 600 NE MAGUIRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Failed	Monday, August 26, 2024

Corrective Action Required:

1	Misc	**The engineer documents submitted to the city, from Everstead and Alpha Omega Geotech, do not show any inspection&approval for the south footing and west foundation wall.
---	------	---

Informational:

3	Misc	Everstead Engineering inspection reports submitted for north and west footing; north and east foundation wall; report indicates ufer located at west foundation wall
---	------	--

Alpha Omega Geotech approved north footing and interior column footings

Comments: