

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235733
Address: 209 SE GREEN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Robb Popp	Failed	Monday, August 26, 2024

Informational:	
1	Misc
	Perimeter footiing
	-Complete
	-Art wall bump outs complete
	Interior pier pds
	-Complete
	Interior footings
	-Complete
	Canopy piers at
	-Complete
	Courtyard retaining wall footings
	-Complete

Corrective Action Required:	
2	Misc
	Transformer enclosure-
	-Provide proper clearance to earth at rebar
	-Remove all loose soil and debris from footing
	-Ensure 3rd party approval for bearing

Comments: