

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241062
Address: 3513 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Kyle Beard	Not Ready	Monday, August 26, 2024

Corrective Action Required:

2	Miscellaneous Correction	-Concrete back deck piers are 25,28,30 and 32 inches deep. Piers are required to be a minimum of 36 inches deep. -Deck piers failed again -Walk your property before rescheduling inspections. -Not ready for inspection
---	--------------------------	---

Comments: