

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215211

Address: 4023 NE SAGAMORE DR, LEES SUMMIT, MO 640644025 NE SAGAMORE DR, LEES SUMMIT, MO  
640644027 NE SAGAMORE DR, LEES SUMMIT, MO 640644021 NE SAGAMORE DR, LEES  
SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Ready for Temp CO	Tuesday, August 27, 2024

Corrective Action Required:

1	Misc	-Bring sewer manhole at front NW lot corner to grade level
---	------	--

825:

-Firecaulk firewall around I beam in basement

\*\*Units 4023 and 4027 not yet inspected

\*\*TCO approved for unit 4021 and 4025only

**Comments:**