CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20221049Address:808 NE ALGONQUIN ST, LEES SUMMIT, MO 64064806 NE ALGONQUIN ST, LEES SUMMIT, MO
64064804 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Tuesday, August 06, 2024
Corrective Action Required:			
1 Misc	EXTERIOR: -Sidewalk not approved on record -Provide swale at both sides of building per plot plan -Final grade, sod, downspout and sump pump extension -Seal exterior wall penetrations; seal above meter, AC disconnect, seal exterior lights, etc		
	Unit 804: -Water meter flush with final grade -Deck beam attachment to post not per code		
	Unit 808: -Nail deck double 2x10 header joist hanger -Fb floor penetration at tub trap		
	**TCO approved for unit 8	04 & 808	
Corrective Action Required: 2 Misc	UNIIT 806		
	- OBTAIN IRRIGATION PERI	ИІТ	

- PAINT GAS PIPING

- COMPLETE SUMP AND DISCHARGE

***OK FOR TCO 806

Comments: