CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242672

Address: 1020 NW PRYOR RD, Unit:E, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underslab Plumbing Inspection Robb Popp Passed Tuesday, August 27,

- Commercial 2024

Corrective Action Required:

1 Miscellaneous Provide pressure test at 5psi or 10' water column

Correction

Comments: