CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241832

Address: 2131 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Kyle Beard Failed Tuesday, August 27,

Residential 2024

Corrective Action Required:

2 Miscellaneous full height 2x6 studs required at each side of front door (upload engineers

Correction letter)

-sister notched exterior wall studs in basement (pony wall)

-address holes drilled closer than 2" to one another (can be inspected at

building occupancy)

Okay to insulate

Comments: