CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20226232Address:120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | | Inspector: | Outcome: | Date: | |
|--------------------------|-----------------------|--|---------------------------|-------------------------------|--|
| Above Ceiling Inspection | | Robb Popp | Partial | Tuesday, August 27, 2024 | |
| Correct | tive Action Required: | | | | |
| 1 | FIRST FLOOR | *****AREAS APPROVED TO COVER: | | | |
| | | Additon complete except as noted: | | | |
| | | *AHU | *AHU | | |
| | | -Address duct penetration/ complete firewall | | | |
| | | **Existing side: | | | |
| | | 1E-314-seal penetrations | | | |
| | | 300C-seal penetrati | | | |
| | | 1E-315-Label firewall | | | |
| | | 1E-313-seal penetrations and label firewall | | | |
| Correct | tive Action Required: | | | | |
| 2 | SECOND FLOOR | Above-ceiling OK be | elow: | | |
| | | -Soffits in waiting ro | oom area and adjacent cor | ridors | |
| | | **Addition Complet | te except as noted below: | | |
| | | -Elevator Lobby | | | |
| Correct | tive Action Required: | | | | |
| 3 | THIRD FLOOR | *****AREAS APPRO | VED TO COVER: | | |
| | | Soffits at 3E-355, 34 | 6, 338, 241, 244, 306 | | |
| | | UNITS 300A, 304-320 |), 361-367,335-349 | | |
| | | Seal penetrations a | nd label smoke/fire walls | at3E-332, 333, 104, Cor 300B, | |

cor-300C, 205, 206, 327, 324,325, 322,323, 321,

Comments: