

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20222424  
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Dustin Agcopra	Partial	Tuesday, August 27, 2024

Informational:

1 Misc

8-19-24 BR Contractor preformed test on MH A-4 pass.  
Also preformed test on MH A-5 pass..

8-20-24 Dustin A, MH A-7 Fail, MH A-8, D-1,A-9,A-10,F-1 Passed, A-11 Fail,

8-21-24 Dustin A, A13-fail, C1-pass,C2-pass,C3-pass,A2-pass, A2-pass,  
B1-pass

8-22-24 Dustin A, MH A3,A11,A13,A7,K3,K2B13 PASS  
B3, L3 FAIL

8-27-24 Dustin A, B3,B2, G1 and L3 Passed

**Comments:**