

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20242574  
Address: 366 NW PATCH CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Robb Popp	Failed	Wednesday, August 28, 2024

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE. REPAIR DOWNED SILT FENCE CLEAN TRASH AND DEBRIS FROM LOT
---	---	--

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	8/28/24  EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -RESTORE EROSION CONTROL METHODS AND MAINTAIN GRAVEL FILTER
---	----------------------------	---

**Comments:**