

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241680
Address: 3220 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|----------------------------|
| All Rough Inspection - Residential | Mitchell Schwarz | Failed | Wednesday, August 28, 2024 |

Corrective Action Required:
1 Misc

-strap top plates in bed 1 where lapped less than 24"
-basement plans do not match as built, revise plans for inspection

Comments: