## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSUBD20222424 Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                             | Inspector:   | Outcome:   | Date:   |
|---|--|--|---|
| Water Line - Construction<br>Inspection | Bobby Richest  | Partial  | Wednesday, August<br>28, 2024   |
| Informational:<br>1 Misc                | SE Bailey PKWY.<br>08-06-24 JMJ Contractor (<br>6+41, line #4 STA 0+00 to<br>8-9-24 BR Contractor (ESS<br>crew installed 300' of 8" r<br>8-16-24 BR Contactor (ESS<br>4+00. 2nd crew installed<br>22+00.<br>8-26-24 BR Contractor (ES<br>16" water main location f<br>8-27-24 BR Contractor (ES<br>to STA. 3+00. | S) installed fire hydrant at S<br>ESS) installed 300' of 8" mai<br>0+60 crossing.<br>) 1st crew installed 400' of 8<br>nain on line 2 STA. 11+00 - S<br>5) 400' of 8" main on line 5 fr<br>500' of 8" main on line 2 fro<br>S) started excavation on SE<br>or boring under road for 8"<br>S) installed 300' of 8" main of<br>S) installed 230' of 8" main of | n on line #2 STA 12+50 to<br>" main on line 13. 2nd<br>TA, 7+00.<br>Fom STA. 0+00 - STA.<br>m STA. 19+00 - STA.<br>Baylie Rd for the existing<br>water main connection.<br>on line 2 from STA. 6+00 |
|   |  |  |   |

2nd crew installed 300' of 8" main on line 4 from STA. 0+00 - STA. 3+00. Boring contractor started and excavated 30' of pipe under SE Bailey Rd.

Comments: