

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232357

Address: 442 SW BRUMMEL RD, LEES SUMMIT, MO 64081444 SW BRUMMEL RD, LEES SUMMIT, MO
64081446 SW BRUMMEL RD, LEES SUMMIT, MO 64081448 SW BRUMMEL RD, LEES
SUMMIT, MO 64081440 SW BRUMMEL RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Shawn Hoffman	Partial	Thursday, August 29, 2024

Corrective Action Required:

1 Misc 440

- Uncover all smoke detectors
- Top step at second floor exceeds the 3/8" variance allowed
- Basement stairs top step over 7 3/4" and exceeds 3/8" variance
- No back flow preventer at water main spigot
- Electrical panel not labeled
- GFCI s will be tested on next visit

Informational:

2 THE FOLLOWING AREAS ARE APPROVED All deck framing for Building 3 440 SW Brummel

Comments: