



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114000, Building Permit - Commercial
Address: 910 NW BLUE PKWY, Unit:R, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|-----------------------------|
| Electrical Service Inspection - Commercial | John Borns | Passed | Wednesday, October 05, 2011 |

Comments: RELEASE ELECTRICAL SERVICE 2ND TIME DUE TO SERVICE CONFIGURATION REVISION REQUIRED BY KCP&L. ONE LB ENTRY TO DISCONNECT ENCLOSURE TO BE SEALED TO PREVENT WATER ENTRY.