

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242857

Address: 1420 SW WINTHROP TER, LEES SUMMIT, MO 64081
1418 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed	Thursday, August 29, 2024

Corrective Action Required:

2	Miscellaneous Correction	Silt fence at the front of the property is damaged and will no longer serve its intended purpose. Repair or replace silt fence
---	--------------------------	--

Full erosion control measures must be maintained until CofO

Comments: