

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20236204  
Address: 2361 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Not Ready	Thursday, August 29, 2024

Corrective Action Required:

1 Misc

- address studs over board for S/E cable in garage
- will check gb bracing at time of dry wall
- address joist above wall in closet landing on non load bearing wall (address one using h2.5)
- rear master bedroom cspf wall missing straps
- strap top plate above 16" lvl at foyer
- fireblock furr down ends in basement (when using unfazed insulation it must be packed tightly and securely)

Comments: