

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241619
Address: 1805 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Thursday, August 29, 2024

Corrective Action Required:

1	Miscellaneous Correction	1805 SW Hightown. Occupancy -Seal all sheet rock gaps for fire blocking in the garage -Basement escape well needs to have more gravel added so the bottom rung of the ladder to gravel is 18 inches or less -Water meter in the front yard appears to be too high for plot elevation -Sod and splash pads are not installed
---	--------------------------	---

Comments: