

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241902
Address: 1704 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Dustin Agcopra	Passed	Thursday, August 29, 2024

Informational:
1 Misc 8-23-24 DP. Crew removed the curb in front of the DW approach. They had adequate aggregate places, 3 dowels on each side of existing curb and expansion joint. Approved to pour.
8-29-24 DA, curb has been poured to city specs. Passed

Comments: