

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20241951

Address: 3191 NW PARAGON PKWY, LEES SUMMIT, MO 64081
3150 NW PARAGON PKWY, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line - Hydrostatic Test	John Jackson	Partial	Thursday, August 29, 2024

Informational:

1 Misc

08/29/31 Thursday JMJ (Rodriguez Const.)

Fire / Domestic waterline pass hydrostatic Test @200psi for 2hours.

Comments: