

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242943  
Address: 2778 SW 11TH TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Friday, August 30, 2024

Corrective Action Required:

1	Misc	-MIN (2) 1/2" DIA. ANCHOR BOLTS INSTALLED PER R403.1.6 W/ 2"x2"x3/16" PLATE WASHER -ANCHOR BLTS TO BE IN MIDDLE THIRD OF SILL PLATE - STRAPS TO BE 2000 LB STRAPS  - SHEETING NAIL PATTERN OK.
---	------	--

Comments: