

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242441
Address: 1220 NW MAIN ST, Unit:E, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Robb Popp	Failed	Friday, August 30, 2024

Corrective Action Required:

1	Misc	*Installation not per plan -Plans show 600 amp CT cabinet and fused disconnect. 400 amp installed -Plans do not show ground and neutral connected at fused disconnect
---	------	---

Comments: