

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242078
Address: 2070 NW LOWENSTEIN DR, Unit:B, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|------------|----------|-------------------------|
| Above Ceiling Inspection | Robb Popp | Failed | Friday, August 30, 2024 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | Partial only *Hard lids approved -REMOVE SCREWS AND SEAL PENETRATIONS IN DRYER DUCT -SEAL FIREWALL PENETRATION AT LOBBY, PATCH HOLES ABOVE HARD LID IN LOBBY 8/30/24 -Complete all MEPs at ACT ceilings |
|---|------|--|

Comments: