

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242331  
Address: 1620 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:       | Outcome: | Date:                       |
|---|------------------|----------|-----------------------------|
| <b>All Rough Inspection - Residential</b> | Mitchell Schwarz | Failed   | Tuesday, September 03, 2024 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | Uncover all items for inspection<br>-fireblock hvac chase to ceiling space at owners entry<br>-add missing stud at hvac chase at owners entry<br>-missing roof boots<br>-sister all over notched wall studs in basement for anchor bolts<br>-provide future vent for basement bath |
|---|------|--|

**Comments:**