LEE'S SUMMIT

DEVELOPMENT SERVICES

Residential Plan Review

September 03, 2024

CLAYTON PROPERTIES GROUP, INC 120 SE 30TH ST LEES SUMMIT, MO 64082 (816) 246-6700

| Permit No: | PRRES20244614 |
|------------------|---|
| Plan Name: | |
| Project Address: | 3437 SE CORBIN DR, LEES SUMMIT, MO 64082 |
| Parcel Number: | 70500040700000000 |
| Location: | COBEY CREEK - 1ST PLATLOT 11 |
| Type of Work: | NEW SINGLE FAMILY |
| Occupancy Group: | RESIDENTIAL, ONE- AND TWO-FAMILY |
| Description: | NEW HOUSE - ROOF TRUSSES - UNCOVERED DECK - UNFINISHED BASEMENT - |

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and/or additional information to the application through the online portal. Please contact the Development Services Department with any questions you may have.

Development Services Department (816) 969-1200

| Plot Plan Review | Reviewed By: Brandon Kalwei | Rejected | | | | | |
|---|--|--|--|--|--|--|--|
| 1. Deck location, with dimensions to p | roperty lines must be provided on the plot | plan. LABEL AS UNCOVERED DECK | | | | | |
| 2. Contours, spot elevations and drain AND S SIDES | age flow arrows (as required) shall be provi | ded on the lot. MISSING HIGH POINTS ON N | | | | | |
| 3. Sidewalks with dimensions must be | provided on the plot plan. LABEL ADA RAM | Р | | | | | |
| 4. A as-graded plot plan per Section 7-160, Code of Ordinances, is required prior to occupancy. | | | | | | | |
| Residential Plan Review | Reviewed By: Brandon Kalwei | Rejected | | | | | |
| 1. | | | | | | | |
| 2. Provide square footage of living area, garage area, unfinished basement area, etc (IRC Section R304) FINISHED AND UNFINISHED, 1ST FLOOR, GARAGE, DECK SQ. FOOTAGES DO NOT MATCH FROM APPLICATION TO PLANS | | | | | | | |

| Planning R | eview RES | Reviewed By: | Pend | ling |
|------------|---------------------|-----------------------------------|-------------------------|--------------------------|
| | 220 SE Green Street | Lee's Summit, MO 64063 816.969.1 | .200 816.969.1201 Fax | cityofLS.net/Development |

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

| Residential Area: | | | | | |
|---|-------|---------------------|------|--|--|
| Residential, Decks | | 147 | 147 | | |
| Residential, Finished basements | | 448 | 448 | | |
| Residential, garage | | 573 | 573 | | |
| Residential, Living Area (Not Finished Base | ment) | 1416 | 1416 | | |
| Residential, Un-Finished basements | | 59 | 59 | | |
| | | | | | |
| Roofing Material | | Number of Bathrooms | 2.5 | | |
| Number of Bedrooms | 3 | Number of Stories | 1 | | |
| Number of Living Units | 1 | Total Living Area | 2084 | | |
| | | | | | |

220 SE Green Street | Lee's Summit, MO 64063 |816.969.1200 | 816.969.1201 Fax | cityofLS.net/Development