

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20241344
Address: 840 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Tuesday, September 03, 2024

Corrective Action Required:

1	Misc	-Complete corrections for LSFD -Provide min 27" knee clearance at water fountain -Provide min 27" knee clearance at restroom sink -Mirrors to be max 40" aff to reflective surface -Provide GFCI protection at suite 110 -Missing cover plates at 102 -Paint rooftop gas line
---	------	---

Comments: