## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20215211 Address: 4023 NE SAGAMORE DR, LEES SUMMIT, MO 640644025 NE SAGAMORE DR, LEES SUMMIT, MO 640644027 NE SAGAMORE DR, LEES SUMMIT, MO 640644021 NE SAGAMORE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential		Khanh Nguyen	Failed	Wednesday, September 04, 2024
Corrective Action Required: 1 Misc		-Bring sewer manhole at front NW lot corner to grade level 4023: -Obtain lawn irrigation permit and submit backflow valve test report to city -Provide sewer tracer wire port at grade		
		Install a weatherproof cover for deck receptacle Provide box extension for all electrical boxes recessed more than 1/4" behind non-combustible wall finish Fix receptacle ground fault condition in laundry		
		-Provide gfci protection for	ovide gfci protection for sprinkler receptacle or install single plug receptacle	
		4025: -Obtain lawn irrigation permit and submit backflow valve test report to city -Firecaulk firewall around I beam in basement		
		-Provide sewer tracer wire	nit and submit backflow val port at grade side of stoop more than 30"	

measured 36" out from edge down to grade

- -Provide a wall receptacle at short wall adjacent to refrigerator
- -Provide box extension for all electrical boxes recessed more than 1/4" behind
- non-combustible wall finish
- -Reinforce north deck post
- -Smoke alarm must be min 10 ft from stove
- -Provide full bearing under triple joists in basement
- -Seal foundation crack under service panel
- -Where's the gfci for the bathroom receptacles?

\*\*TCO approved for unit 4021 and 4025 only

## Comments: