

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240569
Address: 2755 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Passed	Wednesday, September 04, 2024

Informational:

1 Misc

8-23-24 DW was formed, aggregate compacted, need to keep cross slopes throughout driveway approach. Approved to pour.

8-26-24 Dustin A, DW was not poured if not poured before next rain event it will need another pre pour inspection

8-28-24. DW is approved to be poured.

9-3-2024 Dustin A, DW is poured to city specs and slopes are in compliance.
Passed

Comments: