

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232357

Address: 442 SW BRUMMEL RD, LEES SUMMIT, MO 64081444 SW BRUMMEL RD, LEES SUMMIT, MO
64081446 SW BRUMMEL RD, LEES SUMMIT, MO 64081448 SW BRUMMEL RD, LEES
SUMMIT, MO 64081440 SW BRUMMEL RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Shawn Hoffman	Partial	Wednesday, September 04, 2024

Corrective Action Required:

1	Misc	440 - support expansion tank at water heater Ok for staging
---	------	---

Informational:

2	THE FOLLOWING AREAS ARE APPROVED	All deck framing for Building 3 440 SW Brummel - Building 3 garages all rough approved
---	--	---

Corrective Action Required:

3	Misc	442 Brummel - provide security screws at exterior doors hinges and strike plates (2) per hinge 3" - support expansion tank at water heater - handrail at bottom of second floor stairs below 34" Ok for staging
---	------	--

Comments: