

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230994
Address: 1021 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Bobby Richest	Partial	Friday, August 30, 2024

Informational:
1 Misc

5-14-24 BR Erosion control is up and working order

5-23-24 BR Grass needs to be trim down so that public fire hydrant is visible and silt fence is visible and work properly. Also need to use approve gutter buddy's on erosion control plans for inlet protection.

5-29-24 BR Erosion control is up and working order. Grass is trim down and public fire hydrant is visible.

6-4-24 BR Erosion control is up and working order.

6-11-24 BR Erosion control is up and working order.

6-17-24 BR Erosion control is up and working order.

6-26-24 BR Erosion control is up and working order.

7-3-24 BR Erosion control is up and working order.

7-10-24 Erosion control is up and working order.

7-17-24 BR Erosion control is up and working order.

7-26-24 BR Erosion control is up and working order.

8-9-24 BR Erosion control is up and working order.

8-15-24 BR Erosion control is up and working order.

8-30-24 BR Erosion control is up and working order.

9-4-24 BR Erosion control is up and working order.

Comments: