

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236204
Address: 2361 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|------------------------------|
| All Rough Inspection - Residential | Mitchell Schwarz | Failed | Thursday, September 05, 2024 |

Informational:
1 Misc

-will check gb bracing at time of dry wall

Okay to insulate

Comments: