

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20230057

Address: 451 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081443 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081445 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081447 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081449 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081453 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081441 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Shawn Hoffman	Failed	Friday, September 06, 2024

Corrective Action Required:

1	Misc	441 sw Longview
---	------	-----------------

UNits
441,443,445,447,449,451,454

Common items entire building
- Gutters and down spouts and splash pads to divert water 36" away from foundation

445,454 BOTH - Window in second floor bathroom at back of building to be tempered (covered with plexiglass)

*** No Occupancy until all city departments have approved; see planning comments on seperate cover.

Comments:

