

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20232726  
Address: 2200 NE DOUGLAS ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Surface</b>	Devon Perry	Passed	Friday, September 06, 2024

Informational:

1 Misc

7-26-24 DP. ESS is onsite pouring the north turn lane off Douglas. They poured with KCM MB 4K concrete, 10" thick. Broom finish and white cure

9-6-24 DP. ESS finished pouring both turn lanes. All paint has been completed and lane drop has been removed.

**Comments:**