

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240366

Address: 1439 SW WINTHROP TER, LEES SUMMIT, MO 64081
1437 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, September 06, 2024

Corrective Action Required:

1 Misc

-address pending driveway and sidewalk inspections

1437

-address prong broken off in outlet right of oven

-gfc protection for outlet in laundry

-missing afci protection for refrigerator and microwave in kitchen. (23,21 breakers)

-provide lockout for all hardwired appliance breakers

1439

-gfc protection for outlet in laundry

-missing afci protection for refrigerator and microwave in kitchen. (23,21 breakers)

Comments: