

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236029
Address: 827 NE ALGONQUIN ST, LEES SUMMIT, MO 64064829 NE ALGONQUIN ST, LEES SUMMIT, MO
64064825 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, September 09, 2024

Corrective Action Required:

1	Misc	825, 827: OK to rock
		829: -Engineer to address repair for damaged truss above master bed

Comments: