

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241136
Address: 3237 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, September 09, 2024

Corrective Action Required:

1	Misc	-pay all fees -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -identify sewer tracer wire -will check water meter at time of final grade and sod -outlet in pantry not working -afci protection for all circuits in kitchen -A/c being installed at time of inspection, will check at re inspection
---	------	--

Comments: