

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #:PRPWRW20223891, Public Works Right of Way Permit  
Address: 256 NE EDGEWATER DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Site Visit Inspection</b>	Thad Nave	Passed	Monday, September 09, 2024

Corrective Action Required

1	Misc	Driveway depth, forms, and gravel meet specs. This will need an ADA final inspection.
---	------	---

Corrective Action Required

2	Misc	site visited and it appears that ADA does not meet city standards. The sidewalk is as high as 4.1% in areas. The driveway will need to be tore out and replaced to meet ada standards.
---	------	--

Corrective Action Required

3	Misc	Site visited and it appears that driveways has not been tore out and replaced. Since sidewalk does not meet ADA standards
---	------	---

Corrective Action Required

4	Misc	Site visit, Driveway approach does meet ADA requirements
---	------	--

**Comments:**