

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240366

Address: 1439 SW WINTHROP TER, LEES SUMMIT, MO 640811437 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, September 10, 2024

Corrective Action Required:

1 Misc

1437

-missing afci protection for refrigerator and microwave in kitchen. (23,21 breakers)
-provide lockout for all hardwired appliance breakers

1439

-missing afci protection for refrigerator and microwave in kitchen. (23,21 breakers)

Comments: