

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234924
Address: 2782 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, September 10, 2024

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- pending driveway inspection- Land sewer trace wire to grade- Final grading and sod- Provide splash pads , divert water 36" away from foundation- Draft stop gaps at ceiling above garage doors- Uncover all smoke detectors- Address cut joist in basement near furnace by supply duct
---	------	--

Comments: