

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20222424
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Hydrostatic Test	Bobby Richest	Passed	Tuesday, September 10, 2024

Informational:
1 Misc 9-10-24 BR Contractor preformed a hydrostatic test on water line 1 & 2 which is the 1st 4000 line installed. Both water line pass ready for chlorination & disinfection

Comments: