

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20241596
Address: 2807 NW CHIPMAN RD, LEES SUMMIT, MO 64081

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Failed - Stop Work	Tuesday, September 10, 2024

Corrective Action Required
1 Misc

House has been framed, all MEPs installed and sheet rocked.
Walls are finished and fixtures are being installed. Electrical
has not been inspected. No inspections have been performed.
-Remove all sheet rock to expose all framing and MEPs, Expose
underslab plumbing, submit engineered truss plans. Stop Work
until resolved

Comments: