



# Masonry Inspection

Alpha Omega Geotech, Inc  
1701 State Avenue  
Kansas City, KS 66102  
Phone: 913-371-0000

Client:  
Tailor Made Exteriors  
1610 SE Hamblen Rd  
Lee's Summit, MO 64081

Project:  
230445  
TM Fieldhouse  
1600 SE Hamblen Rd  
Lees Summit, MO 64081

**Date:** 08/20/2024

**Inspector:** Bryce Enzbrenner

**Weather:** Cloudy

**Temperature (F):** 70

## OBSERVATIONS

**Location of Masonry Inspected:** South east wall approximately C13.8-A.9/15.8

**Grouted Elevation:** 11 Feet to 15 Feet

**Plans Used:** Structural Plans

**Drawing No.:** S100

**Reinforcing Steel Per Contract Documents:** Yes

**Grout Placement per Contract Documents:** Yes

**Grout Temperature (F):** 65

**Discrepancy:** No

**Remarks:** End grout was 15'4"