

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244003

Address: 225 NW ORCHARD CT, LEES SUMMIT, MO 64063 223 NW ORCHARD CT, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Residential</b>	Robb Popp	Failed	Wednesday, September 11, 2024

Corrective Action Required:

1	Misc	Inspection denied -Backfill around foundation to provide access for inspection
---	------	---

**Comments:**