

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244003

Address: 225 NW ORCHARD CT, LEES SUMMIT, MO 64063223 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------|------------|----------|----------------------------------|
| Erosion Control | Robb Popp | Failed | Wednesday, September 11, 2024 |

Corrective Action Required:

| | | |
|---|---------------------------------------|--|
| 1 | DCM2 ESC DEFICIENT INSTALLATION | DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. -Restore erosion control at front -Provide gravel filter min of 6" lift of min 3/4" gravel -Clean slit and gravel from street |
|---|---------------------------------------|--|

Comments: