

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236296

Address: 2124 SW HOLDBROOKS DR, LEES SUMMIT, MO 64082
2122 SW HOLDBROOKS DR, LEES SUMMIT,
MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Wednesday, September 11, 2024

Corrective Action Required:

3	Miscellaneous Correction	Irrigation permit is required for unit 2124 -Splash pads and sump pump extensions are not installed -Raise water meter to yard height on unit 2124
---	-----------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------

Builder sent in their 2nd TCO extension request. Builder is actively working on their building final. Be sure to look over the list of corrections before scheduling your final building inspection for CofO

Comments: