

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241005  
Address: 1628 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Ready for Temp CO	Wednesday, September 11, 2024

Corrective Action Required:

1	Misc	-address pending driveway inspection -address pending sidewalk inspection -address pending pier inspection -pay all fees -provide as graded plot plan -final grade and sod -will check water meter at time of final grade and sod -sump pump and splash blocks to extend 36" from foundation -obtain issued lawn irrigation permit
---	------	--

Comments: