

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222783
Address: 1231 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line Construction Inspection	John Jackson	Partial	Wednesday, September 11, 2024

Informational:	
1 Misc	12/18/23 Monday JMJ (Central Plumbing-Steve) Contractor has been working on the continued construction of fire line loop as-per project plans. Contractor continued the installation from the Northwest to the South of project building #3. 09/11/24 Wednesday JMJ (Site Rite) Contractor installed approximately 30' of 6" fire line with 45 degree bends.

Comments: