

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244002

Address: 219 NW ORCHARD CT, LEES SUMMIT, MO 64063 217 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Failed	Thursday, September 12, 2024

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	9/11/24 DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. -Restore erosion control at front of lot -Provide gravel filter min of 6" lift of min 3/4" gravel
---	---------------------------------------	---

Corrective Action Required:

2	DCM5 ESC INSP DENIED	9/12/24 REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL INSTALLATION.
---	-------------------------	---

Comments: