

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236294

Address: 2118 SW HOLDBROOKS DR, LEES SUMMIT, MO 64082
2116 SW HOLDBROOKS DR, LEES SUMMIT,
MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Thursday, September 12, 2024

Corrective Action Required:

2	Miscellaneous Correction	Both units have water meters covered by sod
		All other corrections have been completed

Comments: